## ਦਫਤਰ ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰਬਰ 2 ਭ. ਮ. ਸਾਖਾ ਮੋਗਾ

To,

The Principal,

Harward Convent School.

Baghapurana Distt Moga (Punjab) 1

ਨੰਬਰ

115

ਮਿਤੀ 09 04 2024

ਵਿਸਾ:

ਇਮਾਰਤ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਬਾਬਤ 2024-25 ।

ਉਪਰੋਕਤ ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਦਾ ਨਿਰੀਖਣ ਸਬੰਧਤ ਜੂਨੀਅਰ ਇੰਜਨੀਅਰ ਵਲੋਂ ਕੀਤਾ ਗਿਆ । ਬਿਲਡਿੰਗ 2024–25 ਲਈ ਸੁਰੱਖਿਅਤ ਪਾਈ ਗਈ ਹੈ । ਸਕੂਲ ਦੀ ਬਿਲਡਿੰਗ ਸੁਰੱਖਿਅਤ ਹੋਣ ਸਬੰਧੀ ਸਰਟੀਫਿਕੇਟ ਆਪ ਨੂੰ ਮਿਤੀ 31–03–2025 ਤੱਕ ਜਾਰੀ ਕੀਤਾ ਗਿਆ ਹੈ । ਅੱਗੇ ਤੋਂ ਹੇਠ ਲਿਖੀਆ ਹਦਾਇਤਾ ਵਲੋਂ ਵਿਸ਼ੇਸ ਧਿਆਨ ਦਿੱਤਾ ਜਾਵੇ ।

- 1) ਬਿਲਡਿੰਗ ਦੇ ਆਲੇ-ਦੁਆਲੇ ਅਤੇ ਛੱਤਾ ਉਪਰ ਪਾਣੀ ਨਾ ਖੜਾ ਹੋਣ ਦਿੱਤਾ ਜਾਵੇ।
- 2) ਜੇਕਰ ਬਿਲਡਿੰਗ ਵਿਚ ਕਿਸੇ ਕਿਸਮ ਦੀ ਤਰੇੜ ਆ ਜਾਦੀ ਹੈ ਤਾ ਉਸ ਜਗ੍ਹਾ ਨੂੰ ਤੁਰੰਤ ਖਾਲੀ ਕੀਤਾ ਜਾਵੇ ਤੇ ਉਸ ਦੀ ਤੁਰੰਤ ਰਿਪੇਅਰ ਕਰਵਾਈ ਜਾਵੇ ।
- 3) ਕਿਸੇ ਕਿਸਮ ਦੀ ਉਸਾਰੀ ਵਿਚ ਵਰਤੇ ਗਏ ਮਟੀਰੀਅਲ ਦੀ ਜਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ । ਆਪ ਵਲੋਂ ਨੱਥੀ ਨਕਸ਼ੇ ਤੋਂ ਇਲਾਵਾ ਜੇਕਰ ਆਪ ਵਲੋਂ ਵਾਧੂ ਉਸਾਰੀ ਕਰਨੀ ਹੋਵੇ ਤਾ ਉਸ ਦੀ ਮੰਨਜੂਰੀ ਮਹਿਕਮੇ ਵਲੋਂ ਲਈ ਜਾਵੇਗੀ ।
- 4) ਡਾਇਰੈਕਟਰ ਜਨਰਲ ਸਕੂਲ ਸਿੱਖਿਆ ਵਿਭਾਗ ਪੰਜਾਬ ਅਤੇ ਸਟੇਟ ਪ੍ਰੋਜੈਕਟ ਸਰਵ ਸਿੱਖਿਆ ਅਭਿਆਨ ਦੇ ਪੱਤਰ ਨੰਬਰ 75444 ਮਿਤੀ 06–11–2009 ਮੁਤਾਬਿਕ ਸਕੂਲ ਵਿਚ ਅੱਗ ਬੁਝਾਉ ਯੰਤਰ ਠੀਕ ਹਾਲਤ ਵਿਚ ਰੱਖੇ ਜਾਣ । ਕਿਸੇ ਵੀ ਅਣਸੁਖਾਵੀ ਘਟਨਾ ਦੀ ਜਿੰਮੇਵਾਰੀ ਸਬੰਧਤ ਸਕੂਲ ਦੀ ਹੋਵੇਗੀ ।
- 5) ਅਗਲੇ ਸਾਲ 2025–26 ਦੀ ਇੰਨਸਪੈਕਸ਼ਨ ਕਰਾਉਣੀ ਯਕੀਨੀ ਬਣਾਈ ਜਾਵੇ ।

ਨੱਥੀ ਸਰਟੀਫਿਕੇਟ,

ਉਪ ਮੰਡਲ ਇੰਜਨੀਅਰ,

ਉਸਾਰੀ ਉਪ ਮੰਡਲ ਨੰ: 2 ਭ.ਮ. ਸਾਖਾ,

Man 1

14) Requirement for fire Protection Arrangements under NBC
Part -IV
(For Building height Less than 1.5metre)

a) Weather house Real provided.

b) Weather down corner provided.

 c) Weather automatic sprinkler provided.
 d) Weather underground static water storage tank of Capacity 50,000 Ltr.(It converted are excess 1600sqm)

e) Weather over head tank of capacity 10,000 Ltr. Exists.(in case of house real) 20,000 Ltr.

f) Weather one electric and one diesel pump of 3 kg/ cum Pressure of capacity 1620 LPM. One electric pump of Capacity 180LPM exist near underground static tank.

g) Weather a pump 3 Kg/cum preasur & 450/500 LPM Exist near over head tank.

Yes / No Yes / No Yes / No

Yes / No

YES/ No

Yes/ No

Was No Sily Bas

Harward Convent School Bagha Purana (Moga)

School stamp

## $\begin{array}{c} PART-II\\ \text{(To be filled by the S.D.E for PWD (B\&R) Department )} \end{array}$

- a) I have visited the above mentioned school on date 05 04 2024 and have been visually inspected it from all angles of safety and fined it fit for normal used as school buildings.
- b) In case and addition / alteration of expansion and modifications to this building is to be carried out the same be carried out under the supervision of a qualification Engineer and this certificate may be re-obtained after the completion from the undersigned.
- c) In case the building is affected by flood, or if there is settlement of walls/ foundation of sagging of roofs etc. immediate inspection of the undersigned by arranged to check the stability and safety of the building.

d) This building can be safety occupied for normal used upto (indicate upto which it can be used) who up do one Year only (3103/2025)

Chairman
Harward Convent School
Bagha Purana (Moga)

Principal Harward Convent School Bagha Purana (Moga) Sub Divisional Engineer Construction Sub Division No PWD B & R Ber Mogali